

WOODLAND FIRE DEPARTMENT - FIRE PREVENTION
300 First Street
Woodland, CA 95695
530-661-5860 Phone
530-661-5869 Fax

For Inspections call 530-661-5857



RESIDENTIAL FIRE SPRINKLER SYSTEM - RESALE INSPECTION

ADDRESS: 1608 Motta Street

DocuSigned by:
Raymond Roth
D3F9585A632B4C9...

5/25/2023 | 4:34 PM PDT

- | | Yes | No |
|--|-------------------------------------|--------------------------|
| 1. Are supply valves and piping sized and arranged properly? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 2. Is sprinkler riser accessible and maintained with check valve, gauge, test valve and flow switch? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Static Pressure: <u>70</u> Flow Pressure: <u>35</u> | | |
| 3. Are sprinkler heads in good condition? (i.e. not leaking, painted, corroded or obstructed) | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 4. Are escutcheon covers in place? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 5. Have all additions or remodeled areas been properly protected? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 6. Do both interior and exterior alarm devices activate properly? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Alarm activation time: <u>00:01.03</u> | | |
| 7. Has a homeowner's manual been provided for new owners? | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Additional Comments: _____

Yes No This residential fire sprinkler system meets minimum Woodland Fire Department requirements for maintenance and operation.

Note: City of Woodland City Code Section 9A-10-24 requires all necessary repairs be completed prior to the close of escrow.

Inspector: D. Carey

Inspection Fee: \$194.00 Date of Inspection: 5/24/23

Re-inspection Fee: _____ Date of Re-inspection: _____

Received by: Payment Pending - Permit #FIRE-23-00113