

CHIMNEY SERVICE REPORT

2665542

SERVICE PROVIDER:

Village Sweep
 Chimney Cleaning and Repairs Since 1983
 FIREPLACES: WOOD-GAS-PELLET-ELECTRIC
 Napa 257-0777 Solano 429-0777
 Sonoma 545-0777 Contra Costa 925-674-0777
 3042 Rockville Road, Fairfield, CA 94534
 villagechimney@aol.com villagehearth.net
 CA Contractor #974228


CUSTOMER:

Name Wendy Rodriguez - Plata Realty
 Address 3609 Thompson St
 City Fairfield State _____ Zip _____
 Phone (____) 628-3685
 E-mail _____
 Directions to home Betty J. Boudreaux
 10/24/2023 4:40 PM PDT

Technician [Signature]
 Service date 10-18-23 Time 11-1

SYSTEM INFORMATION

Fireplaces, Number of..... 1
 Construction Masonry Factory-built Modular
 Fireplace opening sizes..... 1. _____" x _____" 2. _____" x _____" 3. _____" x _____"
 Heating Appliances, Number of..... 0
 Type..... Insert Freestanding Furnace _____
 Fuel..... Wood Coal Gas Oil _____
 Chimney
 Construction..... Factory-built Masonry Other
 Chimney height 28 feet
 Liner..... Flue tile Stainless Cast Unlined
 Flue sizes..... 8"x8" 8"x13" 13"x13" 8"x17" 13"x17"
 6" Round 8" Round _____
 Last cleaned..... _____ year(s) ago Never Unknown



COMMENTS

Damper works, but will not lock in the closed position. This should not be a problem due to glass doors that control about 80% of draft.

Recommend a cleaning with every cord of wood burned or per NFPA 211 an annual evaluation

ANNUAL INSPECTION

The National Fire Protection Association (NFPA) recommends annual inspection of all fireplaces, chimneys, and vents. The next inspection of your system is scheduled for: 10-24

CUSTOMER VERIFICATION

This report is the result of a visual inspection done at the time of cleaning. It is intended as a convenience to our customer, not as certification of fire worthiness or safety. Since conditions of use and hidden construction defects are beyond our control, no warranty is made for the safety or function of any appliance and none is to be implied.

I have read this form and understand the apparent condition of my fireplace, appliance, chimney, and/or vent system. Furthermore I understand the limitations of this report as given in the paragraph above.

Customer Signature _____ Date _____

INVOICE / RECEIPT

DESCRIPTION	PRICE
<u>Cleaning + evaluation</u>	<u>\$235</u>
<u>Paid Full</u>	
Subtotal	
Total	<u>\$235</u>